

# OPTIMIZATION OF BRADLEY LAKE HYDROPOWER USING LAKE ELEVATION RULE CURVE MODELING

EDMUND PARVIN


SCHOOL OF ENGINEERING, UNIVERSITY OF ALASKA, ANCHORAGE

APRIL 06. 2011

# Outline

- Background
  - Bradley Lake
  - Rule Curves
- Research Goals
- Model Development
  - Components
  - Limitations
  - Testing
- Results

# Bradley Lake Hydro Electric Facility




Earth Images (Google earth, 2010)

# BRADLEY LAKE LEVEL

June 2003 - October 2010

### Winter Production



06-07

07-08

08-09

09-10

HISTORICAL AVERAGE


10-11

# Research Goals

- Maximize Energy Production
- Maximize Winter Production
- Effects of seasonal operational shutdowns
- Use of lake elevation rule curves, as operational constraints to Bradley Lake Hydro Electric Facility

# Rule Curves

- A Rule Curve is a guide established to regulate and manage optimum pool elevations for yearly operations at impoundments. (US ACE, 2010).






# Available Data


Homer Electric Association Provided the following

- Daily Turbine flow data with corresponding energy production (July 23,2003 to Nov. 26, 2009)
- Daily Lake Elevations (June 1,2003 to present)
- Reservoir Storage Table
- Fish bypass release


## Lake Storage Curve




## Computed vs Gaged Flow



## Unit 2 Power Rating Curve




## Rule Curve Lake Elevation





# Water Balance

$\Delta$ Lake Storage (ac-ft) + turbine flow (ac-ft) + fish bypass release (ac-ft) = Total Daily Flow (ac-ft).



# Water Balance

Second Approach:

$$(\sum Q1_{n:n+15}) + (\sum Q2_{n:n+15}) + (\sum Q3_{n:n+15}) - ((V_n - V_{n+15}) / 15) = Q/d \text{ in Ac-ft}$$


Q = Flow into the lake


Q1 = Turbine 1 flow ac-ft/d

Q2 = Turbine 2 flow ac-ft/d


Q3 = Fish Bypass release ac-ft/d

V = lake Storage





# Annual Inflow



# Model

## ⦿ Constraints

- Maximum turbine flow  
3000 ac-ft/d
- Maximum lake  
elevation 1180 ft.
- Intake elevation  
1080 ft.

## ⦿ Limitations


- Model does not draw  
lake down in  
anticipation of a rain  
event
- Model always returns  
model lake elevation  
to rule curve elevation

# Model Test


- The recorded lake elevations from July 23<sup>rd</sup>, 2003 to Nov. 26<sup>th</sup>, 2009 were entered into the model as a rule curve.
- Modeled data was 0.43% higher than actual power generation
- Actual Power Generation= 2,260,689 MWH
- Modeled Power Generation= 2,270,502 MWH
- Difference= 9813 MWH




# Model Testing




# Model Testing




# Time Shift




# Time Shift



# Time Shift




# Time Shift






# Time Shift




# Maximized Production




# Maximized Production

- ◎ 3.99% gains in overall production
- ◎ 93,446-93,868 MWH increase in production
- ◎ Estimated 9.3 million in increased revenue during study period. Assuming 10 cent per kilowatt cost to consumer
- ◎ Produces 97 % of annual production from May to September
- ◎ Drastically reduces winter production


# Maximizing Winter Production



# Results



# Results






# Results

	Actual	Maximum Production	Maximum Winter Production	Rule Curve 58H
		3.99%	2.13%	3.66%
WY04	0.890	0.942	0.925	0.938
WY05	0.915	0.936	0.920	0.929
WY06	0.913	0.945	0.926	0.945
WY07	0.887	0.904	0.887	0.902
WY08	0.852	0.896	0.875	0.897
WY09	0.859	0.924	0.887	0.908

Rule Curve 58h 1169-1140 rise beginning April1. Winter Production-105000MWH

# Results



# Questions